

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. LAB/ MDB /April /49

Dated: 11/04/2026

It is certified that an inspection team headed by Raman Kumar Jha Lab. Asst. (Name of Officers with designation) from PHED Madhubani


inspected the B.N.JHA DON BOSCO CONVENT SCHOOL, KANHAULI, WARD NO-05 JHANJHARPUR DIST- MADHUBANI (BIHAR) PIN 847404.

(Name & Address of the school) on 10-04-2026 (date of inspection) and on the basis of Water Test

Report (Attached) bearing no LAB/APRIL/49 dated 11/04/2026 of Madhubani (PHED Lab)

certified that the B.N.JHA DON BOSCO CONVENT SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.


This certificate is valid till 31.03.2027

Signature with Seal:   
Name : Ashraf Najmi

Designation : Chemist  
Name & Address of the Office / Department : PHED, Madhubani

TO,  
THE PRINCIPAL  
B.N.JHA DON BOSCO CONVENT  
SCHOOL KANHAULI, WARD NO-  
05, JHANJHARPUR, DIST-  
MADHUBANI (BIHAR) PIN 847404.  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**MANAGER**

B.N. JHA DON BOSCO CONVENT SCHOOL  
WARD NO-05, JHANJHARPUR BAZAR  
DIST- MADHUBANI (BIHAR)-847404



**PRINCIPAL**

B.N. JHA DON BOSCO CONVENT SCHOOL  
WARD NO.05. JHANJHARPUR BAZAR  
DIST. MADHUBANI (BIHAR)-847404

**DISTRICT LEVEL WATER TESTING LABORATORY  
P.H.DIVISION, MADHUBANI**

LT No- 49 Date- 11-4-26

Sampling Date:- 10/04/2026  
Testing Date:- 11/04/2026  
Months:- APRIL 2026.


Sample Collected & Submitted by RAMAN JHA


| Sl No.                    | Block       | Panchayat      | Village             | Source of Water | Name of Location/Nearest Person  | PH.     | Tub.   | T.H     | T.A     | Ca     | Mg     | Cl       | Fe   | F     | SO4     | NO3 | TDS      | EC  | AS       | Remarks |
|---------------------------|-------------|----------------|---------------------|-----------------|----------------------------------|---------|--------|---------|---------|--------|--------|----------|------|-------|---------|-----|----------|-----|----------|---------|
| 1                         | JHANJHARPUR | NAGAR PARISHAD | KANHAULI WARD NO-05 | Boring          | B.N.JHA DON BOSCO CONVENT SCHOOL | 7.4     | 2      | 165     | 230     | 26.8   | 27     | 25       | 0.23 | BDL   | 00      | 0.5 | 212      | 310 | NT       |         |
| Min-Max-Permissible Limit |             |                |                     |                 |                                  | 6.5-8.5 | 1.0-05 | 200-600 | 200-600 | 75-200 | 30-100 | 250-1000 | 1.0  | 1-1.5 | 200-400 | 45  | 500-2000 |     | 0.01- NR |         |

\*NT - Not Tested

\*BDL- Below Detection Limit

NOTE:- THIS REPORT IS VALID FOR 6 MONTHS FROM THE DATE OF TESTING.

  
11/04/2026  
Lab Assistant  
District Laboratory, Madhubani



**MANAGER**

B.N. JHA DON BOSCO CONVENT SCHOOL  
WARD NO-05, JHANJHARPUR BAZAR  
DIST- MADHUBANI (BIHAR)-847404



**PRINCIPAL**

B.N. JHA DON BOSCO CONVENT SCHOOL  
WARD NO.05, JHANJHARPUR BAZAR  
DIST MADHUBANI (BIHAR)-847404

  
11/4/26  
Chemist  
District Laboratory, Madhubani